Attestation of Compliance

Reference No.	:	**LCSB04015064S**
Applicant	:	**Logos Lighting Co., Ltd**
Address	:	**5th Floor, Building A, Zhixuanhan Yuanling Industrial Park, Shiyan Town, Baoan District, Shenzhen City, Guangdong Province, China 518108**
Product	:	**Flood light (LED High Mast Light)**
Trade Mark	:	LOGOS LED
Model(s)	:	**SEE ANNEX I**
Parameters	:	**AC 100-277V or AC 100-240V, 50/60Hz, Class I, IP66, ta.40°C, more information see ANNEX I**
Tested according to	:	**EN IEC 60598-1:2021 + A11:2022; EN 60598-2-5:2015**

The submitted products have been tested by us with the listed standards.

This Attestation of Compliance is issued according to the council Directive 2014/35/EU, Referred to as the Low Voltage Directive. It confirms that the listed product complies with all essential requirements of the LVD Directive and applies only to the sample and its technical documentation submitted to Shenzhen Southern LCS Compliance Testing Co., Ltd. for testing.

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product.Other relevant Directives have to be observed.

CE

Date of issue: April 29, 2025

LCS TESTING LABORATORY APPROVED

Manager

Shenzhen Southern LCS Compliance Testing Co., Ltd.
Room 101-201, Building 39, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, Guangdong, China
Tel: (86)0755-29871520 Fax: (86)0755-29871521
Http://www.lcs-cert.com Email: webmaster@lcs-cert.com

ANNEX I:

Reference No. : LCSB04015064S

Model(s) :

Model No.	Rating
LGS-FLCR-30W	100-277VAC, 50/60Hz, 30W
LGS-FLCR-50W	100-277VAC, 50/60Hz, 50W
LGS-FLCR-100W	100-277VAC, 50/60Hz, 100W
LGS-FLCR-150W	100-277VAC, 50/60Hz, 150W
LGS-FLCR-200W	100-277VAC, 50/60Hz, 200W
LGS-FLCR-240W	100-277VAC, 50/60Hz, 240W
LGS-FLCR-300W	100-277VAC, 50/60Hz, 300W
LGS-FLCR-400W	100-277VAC, 50/60Hz, 400W
LGS-FLCR-500W	100-277VAC, 50/60Hz, 480W
LGS-FLCR-30WB	100-277VAC, 50/60Hz, 30W
LGS-FLCR-50WB	100-277VAC, 50/60Hz, 50W
LGS-FLCR-100WB	100-277VAC, 50/60Hz, 100W
LGS-FLCR-150WB	100-277VAC, 50/60Hz, 150W
LGS-FLCR-200WB	100-277VAC, 50/60Hz, 200W
LGS-FLCR-240WB	100-277VAC, 50/60Hz, 240W
LGS-FLCR-300WB	100-277VAC, 50/60Hz, 300W
LGS-FLCR-400WB	100-277VAC, 50/60Hz, 400W
LGS-FLCR-500WB	100-277VAC, 50/60Hz, 480W
LGS-GSHL-400W	100-240VAC, 50/60Hz, 400W
LGS-GSHL-500W	100-240VAC, 50/60Hz, 480W
LGS-GSHL-600W	100-240VAC, 50/60Hz, 600W
LGS-GSHL-800W	100-240VAC, 50/60Hz, 800W
LGS-GSHL-1000W	100-240VAC, 50/60Hz, 960W
LGS-GSHL-1200W	100-240VAC, 50/60Hz, 1200W

CE

LCS TESTING LABORATORY APPROVED

Shenzhen Southern LCS Compliance Testing Co., Ltd.
Room 101-201, Building 39, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, Guangdong, China
Tel: (86)0755-29871520 Fax: (86)0755-29871521
Http://www.lcs-cert.com Email: webmaster@lcs-cert.com